



NOTES:

1. METER BOXES TO BE PLACED ON BACK SIDE OF DITCH.
2. ALL SERVICE LINES ARE TO BE PLACED OVER EXISTING GAS LINES.
3. UP TO 2" DIA. SERVICE TUBING TO BE COPPER. LARGER SERVICE LINES MUST BE DUCTILE IRON.
4. DEVELOPER/CONTRACTOR IS REQUIRED TO PERFORM HYDROSTATIC PRESSURE TESTS IN ACCORDANCE WITH SECTION 02660-WATER DISTRIBUTION SYSTEMS, OF THE TOWN OF BRASELTON STANDARD SPECIFICATIONS (LATEST EDITION).

TOWN OF BRASELTON WATER & SEWER DEPARTMENTS

JOB TITLE STANDARD DETAIL	SHEET TITLE SERVICE INSTALLATION (PAVED ROADWAY)	DRN. BY: EMI	REV. NO.	BY	DATE
		CKD BY:			
		APPD. BY:			
		DATE: MARCH 2004			
		DETAIL No. W-17	FILE No. 03033\W-17.dwg	SCALE: N.T.S.	