



DETAIL NOTES:

1. POST HYDRANTS SHALL BE NONFREEZING SELF-DRAINING TYPE WITH A MINIMUM 3 FT BURY.
2. HYDRANTS SHALL BE FURNISHED WITH A 2" FIP INLET, A NON-TURNING OPERATING ROD, AND SHALL BE OPEN TO THE LEFT.
3. ALL OF THE WORKING PARTS SHALL BE OF BRONZE TO BRONZE DESIGN AND SHALL BE SERVICEABLE FROM ABOVE GRADE WITH NO DIGGING.
4. OUTLET SHALL BE BRONZE AND BE 2 1/2" NST.
5. HYDRANTS SHALL BE LOCKABLE TO PREVENT UNAUTHORIZED USE.
6. HYDRANTS SHALL BE MAINGUARD NO 77 AS BY KUPFERLE FOUNDRY CO. OR APPROVED EQUAL.

TOWN OF BRASELTON WATER & SEWER DEPARTMENTS

JOB TITLE	SHEET TITLE	DRN. BY: EMI	REV. NO.	BY	DATE
		CKD BY:			
STANDARD DETAIL	FLUSH HYDRANT	APPD. BY:			
		DATE: July 2007			
		DETAIL No. W-33	FILE No. 03033\W-33.dwg	SCALE: N.T.S.	