



**SECTION VIEW
LIFT STATION**

1. Wetwell levels for pump-on-off based on requirements set forth by ANSI/HI Standard 9.8-1998-American National Standard for Pump intake Design by the Hydraulic Institute.
2. Minimum submergence of pump intake based on requirements set forth by ANSI/HI Standard 9.8-1998-American National Standard for Pump intake Design by the Hydraulic Institute.
3. Over the life of the design, the Roughness Factor C may range from C = 130 to C = 150.

TOWN OF BRASELTON WATER & SEWER DEPARTMENTS

JOB TITLE STANDARD DETAIL	SHEET TITLE LIFT STATION SECTION VIEW WETWELL-VAULT		DRN. BY: EMI	REV. NO. BY DATE
	DETAIL No. PS-5		CKD BY: EMI	A EMI 3/13/07
		APPD. BY: EMI	B EMI 03/05/18	
		DATE: JANUARY 2006		
		FILE No. 030331PS-5.dwg		SCALE: N.T.S.