

RUBBERIZED BOOT,
SEAL AND CLAMP

EXISTING TABLES SHALL
BE MODIFIED AS REQUIRED

SLOPE

FORCE MAIN
INLET

GRAVITY SEWER
OUTLET

DEAD END MANHOLE

FORCE MAIN
INLET

FLG. BELL MOUTH
90° BEND

RUBBERIZED BOOT,
SEAL AND CLAMP

24" MAX.
12" MIN.

GRAVITY SEWER
OUTLET

MID STREAM MANHOLE

NOTES:

1. EXISTING MANHOLES SHALL BE CORED FOR FORCE MAIN INSTALLATION. NO MANHOLE SHALL BE CORED WITHOUT TOWN APPROVAL AND TOWN PERSONNEL ON SITE DURING THE CORING.
2. THE MANHOLE WHERE A FORCEMAIN TIES INTO SHALL BE COATED AS PER SPECIFICATION SECTION 2602, OR 2603. THIS APPLIES TO NEW MANHOLES AS WELL AS EXISTING ONES.

TOWN OF BRASELTON WATER & SEWER DEPARTMENTS

JOB TITLE STANDARD DETAIL	SHEET TITLE FORCE MAIN TO MANHOLE CONNECTION	DRN. BY: EMI	REV. NO.	BY	DATE
		CKD BY:	B	EMI	04/15/18
		APPD. BY:			
		DATE: SEP. 2004			
		DETAIL No. PS-9	FILE No. 03033\PS-9.dwg	SCALE: N.T.S.	