



**NOTE:**

1. SEE SPECIFICATIONS SECTIONS 02661 FOR TYPE AND SIZE OF AIR RELEASE VALVE.
2. ALL PIPE & VALVES SHALL BE PAINTED PANTONE PURPLE 522 W/ A SUNLIGHT STABLE PIGMENT

**TOWN OF BRASELTON WATER & SEWER DEPARTMENTS**

JOB TITLE  STANDARD DETAIL	SHEET TITLE  <b>REUSE AIR RELEASE VALVE</b>	DRN. BY: EMI	REV. NO.	BY	DATE
		CKD BY:	A	EMI	7/30/18
		APPD. BY:			
		DATE: JUNE 2018			
		DETAIL No. R-11	FILE No. 03033\R-11.dwg	SCALE: N.T.S.	