



NOTE:

1. TOP OF METER MUST BE A MINIMUM OF 12" FROM THE TOP OF THE METER BOX.
2. CURB STOP SHALL BE LOCATED SO VALVE IS ACCESSIBLE AND CAN BE OPERATED.
3. SEE SPECIFICATION 02666 FOR SPECIFIC REQUIREMENTS.
4. METERS SHALL BE SET BETWEEN SIDEWALKS AND HOUSE, AND IN BACK OF 10' UTILITY EASEMENTS WHERE APPLICABLE .
5. METER BOX SHALL BE PANTONE PURPLE AND READ "RECLAIMED WATER"
6. CORPORATION STOP AND CURB STOP SHALL BE STAMPED WITH THE WORDS "RECLAIMED WATER" BY MANUFACTURER.

TOWN OF BRASELTON WATER & SEWER DEPARTMENTS

JOB TITLE STANDARD DETAIL	SHEET TITLE REUSE 1 -INCH AND SMALLER SHORTSIDE SERVICE CONNECTION (WITH METER)	DRN. BY: EMI	REV. NO.	BY	DATE	
		CKD BY:	A	EMI	02/08/19	
		APPD. BY:				
		DATE: MARCH 2004				
		DETAIL No. R-15	FILE No. 03033\R-15.dwg	SCALE: N.T.S.		