



**NOTE:**

1. TOP OF METER MUST BE A MINIMUM OF 12" FROM THE TOP OF THE METER BOX.
2. CURB STOP SHALL BE LOCATED SO VALVE IS ACCESSIBLE AND CAN BE OPERATED.
3. SEE SPECIFICATION 02666 FOR SPECIFIC REQUIREMENTS.
4. METER BOX AND LID SHALL BE PANTONE PURPLE AND READ "RECLAIMED WATER"
5. CORPORATION STOP AND CURB STOP SHALL BE STAMPED WITH THE WORDS "RECLAIMED WATER" BY MANUFACTURER.

**TOWN OF BRASELTON WATER & SEWER DEPARTMENTS**

JOB TITLE  STANDARD DETAIL	SHEET TITLE <b>REUSE 2-INCH SERVICE CONNECTION (WITH METER)</b>	DRN. BY: EMI	REV. NO.	BY	DATE
		CKD BY:	A	EMI	7/30/18
		APPD. BY:			
		DATE: JUNE 2018			
		DETAIL No. R-16	FILE No. 03033\R-16.dwg	SCALE: N.T.S.	