



NOTES:

1. METER BOXES TO BE PLACED ON BACK SIDE OF DITCH.
2. ALL SERVICE LINES ARE TO BE PLACED OVER EXISTING GAS LINES.
3. SEE SPECIFICATION 02666 FOR SPECIFIC REQUIREMENTS.
4. DEVELOPER/CONTRACTOR IS REQUIRED TO PERFORM HYDROSTATIC PRESSURE TESTS IN ACCORDANCE WITH SECTION 02661—REUSE WATER DISTRIBUTION SYSTEMS, OF THE TOWN OF BRASELTON STANDARD SPECIFICATIONS (LATEST EDITION).
5. SEE DETAIL R-14 FOR LONGSIDE SERVICES, AND R-15 FOR SHORTSIDE SERVICES.

TOWN OF BRASELTON WATER & SEWER DEPARTMENTS

JOB TITLE STANDARD DETAIL	SHEET TITLE REUSE SERVICE INSTALLATION (PAVED ROADWAY)	DRN. BY: EMI	REV. NO.	BY	DATE
		CKD BY:	A	EMI	02/09/19
		APPD. BY:			
		DATE: JUNE 2018			
		DETAIL No. R-17	FILE No. 03033\R-17.dwg	SCALE: N.T.S.	