



NOTES:

1. ALL PIPING INSIDE VAULT SHALL BE FLANGED.
2. MAINLINE METER SHALL BE NEPTUNE WITH BRONZE STRAINER- SIZE AND TYPE COORDINATED WITH TOWN, METER SHALL FEATURE REMOTE READING SYSTEM - PROREAD AUTO DETECT WITH R-900 RF PIT MIU. METER MUST READ IN US GALLONS. SHOP DRAWING MUST BE SUBMITTED TO TOWN FOR APPROVAL PRIOR TO INSTALLATION.
3. DISMANTLING JOINT BY VIKING JOHNSON.
4. RADIO READ PAD SHALL BE MOUNTED ON TOP OF METER VAULT AS PER/MANUFACTURER'S RECOMMENDATIONS.
5. *VAULT SHALL BE SIZED AS PER MINIMUM CLEARANCES SHOWN.
6. SHALL BE PAINTED PANTON PURPLE 522 W/ A SUNLIGHT STABLE PIGMENT

SEE SPECIFICATION 02666 FOR SPECIFIC REQUIREMENTS

TOWN OF BRASELTON WATER & SEWER DEPARTMENTS

JOB TITLE STANDARD DETAIL	SHEET TITLE REUSE 3-INCH AND LARGER METER CONNECTIONS	DRN. BY: EMI	REV. NO.	BY	DATE
		CKD BY:	A	EMI	7/30/18
		APPD. BY:			
		DATE: JUNE 2018			
	DETAIL No. R-20	FILE No. 03033\R-20.dwg	SCALE: N.T.S.		