



NOTES:

1. CAST IRON COVER TO BE STAMPED "REUSE" FOR REUSELINE VALVES.
2. INSTALL NON-METALLIC TAPE APPROXIMATELY 24" ABOVE PIPE
3. DEBRIS CAP MUST BE INSTALLED AT TOP OF VALVE BOX.
4. TRENCH ADAPTOR MAY BE INSTALLED IN PLACE OF VALVE BOX AND DEBRIS CAP. SEE SECTION 2661.
5. NO VALVE SHALL BE INSTALLED IN CONCRETE FINISHED SURFACE OR IN SIDEWALK.
6. VALVE BOX & COVER SHALL BE PAINTED PANTONE PURPLE 522 W/ A SUNLIGHT STABLE PIGMENT.

TOWN OF BRASELTON WATER & SEWER DEPARTMENTS

JOB TITLE STANDARD DETAIL	SHEET TITLE REUSE VALVE BOX	DRN. BY: EMI	REV. NO.	BY	DATE
		CKD BY:	A	EMI	7/30/18
		APPD. BY:			
		DATE: JUNE 2018			
	DETAIL No. R-8	FILE No. 03033\R-8.dwg	SCALE: N.T.S.		