



SPACER DETAIL

END SEAL DETAIL

NOTE: SPACERS REQUIRED AT EACH END OF CASING, AT BELLS,
AND IN THE MIDDLE OF EACH JOINT OF PIPE.

THIS DETAIL APPLIES TO BURIED APPLICATIONS ONLY.
ABOVE GROUND INSTALLATIONS SHALL BE UV PROTECTED.

TOWN OF BRASELTON WATER & SEWER DEPARTMENTS

JOB TITLE STANDARD DETAIL	SHEET TITLE CASING DETAIL	DRN. BY: EMI	REV. NO.	BY	DATE
		CKD BY:	A	EMI	1/9/09
		APPD. BY:			
		DATE: JUNE 2006			
		DETAIL No. S-16	FILE No. 03033\S-16.dwg	SCALE: N.T.S.	