



NOTES:

1. AERIAL CROSSINGS MUST BE APPROVED BY TOWN ENGINEER.
2. PIPE CONNECTIONS (I.E. JOINTS) SHALL NOT BE EXPOSED ON AERIAL LINES, EXCEPT WITH PIERS.
3. CASING IS REQUIRED ON ALL EXPOSED AERIAL LINES.
4. CASING SPACES & END SEALS PER DETAIL S-16 REQUIRED

TOWN OF BRASELTON WATER & SEWER DEPARTMENTS

JOB TITLE STANDARD DETAIL	SHEET TITLE NON-PIER AERIAL D.I.P. SEWER LINE	DRN. BY: EMI	REV. NO.	BY	DATE
		CKD BY:			
		APPD. BY:			
		DATE: SEP. 2004			
		DETAIL No. S-27	FILE No. 03033\S-27.dwg	SCALE: N.T.S.	