



NOTE

MANHOLE SHALL BE INSTALLED LIKE STANDARD PRECAST MANHOLE, EXCEPT FOR DROP.

AN OUTSIDE DROP MANHOLE SHOULD BE PROVIDED FOR A SEWER ENTERING A MANHOLE AT AN ELEVATION OF 24 INCHES OR MORE ABOVE THE MANHOLE INVERT. WHEN THE DIFFERENCE IN ELEVATION BETWEEN INCOMING SEWER AND MANHOLE INVERT IS LESS THAN 24 INCHES THE INVERT SHOULD FILLETED TO PREVENT SOLIDS DEPOSITION.

MAXIMUM ALLOWABLE DROP FOR LOWER INLET ON OUTSIDE DROP MANHOLES SHALL BE 24 INCHES.

ALL DROP MANHOLES SHALL BE COATED PER SPECIFICATION 02603

DEVELOPER/CONTRACTOR IS REQUIRED TO PERFORM VACUUM TESTS IN ACCORDANCE WITH SECTION 02601-MANHOLES, OF THE TOWN OF BRASELTON STANDARD SPECIFICATIONS (LATEST EDITION)

TOWN OF BRASELTON WATER & SEWER DEPARTMENTS

JOB TITLE STANDARD DETAIL	SHEET TITLE OUTSIDE DROP MANHOLE	DRN. BY: EMI	REV. NO.	BY	DATE
		CKD BY:	1		09/13/18
		APPD. BY:			
		DATE: SEP. 2004			
		DETAIL No. S-6	FILE No. 03033\S-6.dwg	SCALE: N.T.S.	