



**NOTE:**

1. TOP OF METER MUST BE A MINIMUM OF 12" FROM THE TOP OF THE METER BOX.
2. CURB STOP SHALL BE LOCATED SO VALVE IS ACCESSIBLE AND CAN BE OPERATED.
3. SEE SPECIFICATION 02665 FOR SPECIFIC REQUIREMENTS.

**TOWN OF BRASELTON WATER & SEWER DEPARTMENTS**

JOB TITLE  STANDARD DETAIL	SHEET TITLE	DRN. BY: EMI	REV. NO.	BY	DATE
	<b>2-INCH SERVICE CONNECTION (WITH METER)</b>	CKD BY:			
		APPD. BY:			
		DATE: JULY 2007			
	DETAIL No. W-16	FILE No. 03033W-16.dwg	SCALE: N.T.S.		