



**NOTES:**

1. METER BOXES TO BE PLACED ON BACK SIDE OF DITCH.
2. ALL SERVICE LINES ARE TO BE PLACED OVER EXISTING GAS LINES.
3. SEE SPECIFICATION 02665 FOR SPECIFIC REQUIREMENTS.
4. DEVELOPER/CONTRACTOR IS REQUIRED TO PERFORM HYDROSTATIC PRESSURE TESTS IN ACCORDANCE WITH SECTION 02660—WATER DISTRIBUTION SYSTEMS, OF THE TOWN OF BRASELTON STANDARD SPECIFICATIONS (LATEST EDITION).
5. SEE DETAIL W-14 FOR LONGSIDE SERVICES, AND W-15 FOR SHORTSIDE SERVICES.

**TOWN OF BRASELTON WATER & SEWER DEPARTMENTS**

JOB TITLE  STANDARD DETAIL	SHEET TITLE <b>SERVICE INSTALLATION (PAVED ROADWAY)</b>	DRN. BY: EMI	REV. NO.	BY	DATE
		CKD BY:	A	EMI	02/08/19
		APPD. BY:			
		DATE: MARCH 2004			
		DETAIL No. W-17	FILE No. 03033W-17.dwg	SCALE: N.T.S.	