



NOTE:
MEGALUGS OR MJ-FIELD LOK WITH BLOCKING
REQUIRED ON ALL FITTINGS.

SHEET 2 of 5

NOTE:
DEVELOPER/CONTRACTOR IS REQUIRED TO PERFORM HYDROSTATIC PRESSURE
TESTS IN ACCORDANCE WITH SECTION 02660-"WATER DISTRIBUTION SYSTEMS",
OF THE TOWN OF BRASELTON STANDARD SPECIFICATIONS (LATEST EDITION).

TOWN OF BRASELTON WATER & SEWER DEPARTMENTS

| | | | | | |
|-----------------|---|------------------------|---------------|----|------|
| JOB TITLE | SHEET TITLE | DRN. BY: EMI | REV. NO. | BY | DATE |
| STANDARD DETAIL | THRUST BLOCKING DIMENSIONS (200 psi LINE PRESSURE) | CKD BY: | | | |
| | | APPD. BY: | | | |
| | | DATE: MARCH 2004 | | | |
| | DETAIL No. W-2 | FILE No. 03033 W-4.dwg | SCALE: N.T.S. | | |