



NOTES:

1. ALL PIPING INSIDE VAULT SHALL BE FLANGED.
2. MAINLINE METER SHALL BE NEPTUNE TRU/FLOW COMPOUND WITH BRONZE STRAINER- SIZE TO BE COORDINATED WITH TOWN, METER SHALL FEATURE REMOTE READING SYSTEM - PRORREAD AUTO DETECT WITH R-900 RF PIT MIU. METER MUST READ IN US GALLONS. SHOP DRAWING MUST BE SUBMITTED TO TOWN FOR APPROVAL PRIOR TO INSTALLATION.
3. DISMANTLING JOINT BY VIKING JOHNSON.
4. DOUBLE CHECK ASSEMBLY SHALL BE SERIES BY WATTS, AMES OR APPROVED EQUAL. SHOP DRAWING MUST BE SUBMITTED TO TOWN FOR APPROVAL PRIOR TO INSTALLATION.
5. RADIO READ PAD SHALL BE MOUNTED ON TOP OF METER VAULT AS PER/MANUFACTURER'S RECOMMENDATIONS.
6. *VAULT SHALL BE SIZED AS PER MINIMUM CLEARANCES SHOWN.

SEE SPECIFICATION 02665 FOR SPECIFIC REQUIREMENTS

TOWN OF BRASELTON WATER & SEWER DEPARTMENTS

JOB TITLE STANDARD DETAIL	SHEET TITLE 3-INCH AND LARGER METER CONNECTIONS DOMESTIC ONLY	DRN. BY: EMI	REV. NO.	BY	DATE
		CKD BY:	A	EMI	9/13/18
		APPD. BY:			
		DATE: JUNE 2006			
	DETAIL No. W-20	FILE No. 03033\W-20.dwg	SCALE: N.T.S.		