



SEE SPECIFICATION 02665 FOR SPECIFIC REQUIREMENTS FOR DOMESTIC LINE.

FIRELINE NOTES

1. ALL FIRELINE PIPING INSIDE VAULT SHALL BE FLANGED.
2. MAINLINE METER SHALL BE NEPTUNE HIGH PROTECTUS III FIRE SERVICE METER- SIZE TO BE COORDINATED WITH TOWN, METER SHALL FEATURE REMOTE READING SYSTEM - PROREAD AUTO DETECT WITH R-900 RF PIT MIU. METER MUST READ IN US GALLONS. SHOP DRAWING MUST BE SUBMITTED TO TOWN FOR APPROVAL PRIOR TO INSTALLATION.
3. DISMANTLING JOINT BY VIKING JOHNSON.
4. DOUBLE CHECK ASSEMBLY SHALL BE SERIES BY WATTS, AMES OR APPROVED EQUAL. SHOP MUST BE SUBMITTED TO TOWN FOR APPROVAL PRIOR TO INSTALLATION.
5. RADIO READ PAD SHALL BE MOUNTED ON TOP OF METER VAULT AS PER/MANUFACTURER'S RECOMMENDATIONS.
6. *VAULT SHALL BE SIZED AS PER MINIMUM CLEARANCES SHOWN.
7. ALL GATE VALVES SHALL HAVE RISING STEMS.

TOWN OF BRASELTON WATER & SEWER DEPARTMENTS

DRN. BY: EMI	REV. NO.:	BY:	DATE:
CKD BY:	A	EMI	01/22/19
APPD. BY:			
DATE: JUNE 2006			
FILE No. 03033W-21.dwg			SCALE: N.T.S.
SHEET TITLE			
3-INCH AND LARGER METER CONNECTIONS ONLY OR FIRELINE ONLY OR FIRELINE/DOMESTIC			
JOB TITLE			
STANDARD DETAIL			
DETAIL No. W-21			